

5/8" DIA. X 10" ANCHOR BOLT, MIN.
 EMBEDMENT OF 7" W/ 3" SQ. X 1/4" THICK
 PLATE WASHERS @ 6' O.C. TYPICAL; MIN. 2
 BOLTS PER PIECE; W/ 1 BOLT LOCATED NOT
 LESS THAN 7 BOLT DIAMETERS TO OR GREATER
 THAN 12" FROM END;
 PER CBC SEC 2308.12.8

MIN. 3.5" THICK CONC. SLAB W/ #3 REBAR
 @ 18" O.C. EACH WAY OR 6X6#10-10 WWF
 CENTERED IN SLAB

PAD ELEVATION

2X EXTERIOR
 BEARING
 WALLS

2X PRESSURE
 TREATED
 #2 DF SILL
 PLATE

8" MIN. PER CBC
 SEC. 2304.11.2.2

FIN. GRADE

12" MIN.
 18" IF EXPANSIVE
 SOIL

2" SAND O/ 6 MIL VAPOR
 BARRIER O/ 4" CRUSHED
 ROCK

MIN. 2 #4 REBAR
 CONTINUOUS
 TOP & BOTTOM;
 LAP ALL SPLICES
 MIN. 40 DIAM.

3"

12" MIN. 1 STORY
 15" MIN. 2 STORY
 18" MIN. 3 STORY

**EXTERIOR FOOTING
 (SLAB)**

2007 CBC

DETAIL ##

DATE: 2/08

REVISED:

THIS DETAIL APPROVED BY:

FAIRFIELD _____	SUISUN _____	DAVIS _____
VACAVILLE _____	NAPA _____	NAPA CO. _____
DIXON _____	RIO VISTA _____	SOLANO CO. _____
BENECIA _____	VALLEJO _____	MARTINEZ _____
WINTERS _____	AM. CANYON _____	WOODLAND _____